

I.C.R. Water Co. Monthly Operator Notes
April 2022

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested

75 blue stake ticket were completed

(14) New meter installs (5) TRR (9) ICR

TRR well #2 is down. We are waiting for the rehabilitation the equipment is on hand and the well should be back on-line by mid-May

Emergency call out at Cooper Morgan boost station due to APS

We are getting a bid for the booster pumps at Cooper Morgan Boost station from National Pump

Weed abatement has started for the year

Lake line is on 8hrs. per day @430 gpm

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

“Open Projects”

TRR Well #2: estimated cost 24k/completion estimate mid-May

Cooper Morgan Booster Pump rebuild/replace: waiting on cost estimate and completion

Spare well pump and motor TRR well #1: cost estimate 11k/ completion upon approval

