

I.C.R. Water Co. Monthly Operator Notes  
June 2022

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested, Derek is working with Richard on the SOP's

88 blue stake ticket were completed

(7) New meter installs (0) TRR (7) ICR

New well is drilled and should be on-line in mid to late July

2 emergency call outs TRR Wells

Weed abatement is ongoing

Cooper Morgan Boost station pump rehab. has started the first pump is back on-line and the second has been pulled and is being rebuilt now

Molly Way boost station code is being updated for the fill valve

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time, except the TRR well #2

“Open Projects”

Mission control update is on-going

Molly Way code upgrade

Cooper Morgan Booster Pump rebuild/replace: estimated cost 69k/first pump is back online 2<sup>nd</sup> is being rebuilt now

Spare well pump and motor TRR well #1: cost estimate 11k/ completion upon approval

Spare pump and motor for Magner boost station 9k/6-8 weeks approved

