

ICR Water Co.

Operation Report for the Month of November 2022

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- System wide engineering review is on-going with Civil Tech Engineering
- All data requested at the last review meeting has been submitted
- 7 new meter installs (7) TRR
- Failed equipment for ICR Well #2 is at the manufacturer to be evaluated
- Electrical issue with TRR well #4 was evaluated and parts will be here mid-December
- Mission control upgrades are being completed, Double Adobe boost station is the final site
- 0 emergency call outs
- Spare well pump and motor for ICR wells were delivered
- 65 Blue Stakes orders were completed
- We are compiling a list of valve monuments that are compromised and need replacing
- We had a contractor look at the TRR #4 and is getting us a proposal for concrete work
- Board approved proposal for building at TRR well #4
- 970 meters were read system wide

Open Projects

- Mission Control upgrades (Double Adobe boost station) 9k/ expected completion 12/22
- Tank inspection and cleaning for all tanks 6k/ expected completion 12/22
- Pull equipment and inspect TRR well #1 7k/expected completion, upon Board approval
- Complete system wide mission control /pricing and completion TBD*
- Golf course lake PVC valve/ pricing and completion TBD*
- Security Fence at Cooper Morgan site/ pricing and completion TBD*
- Installation of AC units at well control houses/ pricing and completion TBD *
- Installation of strategic locations for valves/ pricing and completion TBD*
- Add level transducers to Wells/ pricing and completion TBD*
- Add heating and Lighting to ICR well #2 pump house/ pricing and completion TBD*
- Eye wash stations at well houses / pricing and completion TBD*
- Ventilation at well houses/ pricing and completion TBD *
- * tasks generated from Civil Tech review

Water Testing

Analysis Name	Month	# of samples	result
Monthly Microbiology	October 2022	4	Absent
PFAS	October 2022	(1) TRR (1) ICR	Non-detect Non-detect