

ICR Water Co.

Operation Report for the Month of January 2023

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- System wide engineering review is on-going with Civil Tech Engineering
- All data requested at the last review meeting has been submitted
- Attended annual meeting
- Failed equipment for ICR Well #2 motor was replaced under warranty
- Water line repair in TRR on Escalante was repaired
- PPE cabinets and eyewash stations have been installed at all well sites
- 5 emergency call outs
- 54 Blue Stakes were completed
- We are still attempting to get a bids for concrete work at TRR well #4
- New batteries at Magner tank were installed
- ACC tour was completed
- 971 meters were read system wide

Open Projects

- Pull equipment and inspect TRR well #1 7k/expected completion 2/23
- Complete system wide mission control /pricing and completion TBD*
- Golf course lake PVC valve/ pricing and completion TBD*
- Security Fence at Cooper Morgan site/ pricing and completion TBD*
- Installation of AC units at well control houses/ pricing and completion TBD *
- Installation of strategic locations for valves/ pricing and completion TBD*
- Add level transducers to Wells/ pricing and completion TBD*
- Add heating and Lighting to ICR well #2 pump house/ pricing and completion TBD*
- Ventilation at well houses/ pricing and completion TBD *
- * tasks generated from Civil Tech review

Water Testing

Analysis Name	Month	# of samples	result
Monthly Microbiology	December 2022	4	Absent
