

ICR Water Co.

Operation Report for the Month of September 2023

Overall Operations

- General maintenance and operations are on-going
 - Easement roads are checked for issues with the transmission lines
 - Molly way flushing and fire pump exercise
 - Yearly Valve exercise program has started
 - System wide engineering tasks are starting
 - M.A.P. testing was completed
 - Repairs were made on the air compressor at the Molly Way Boost Station
 - 4 new meters were installed (3) ICR/ Whispering Canyon (1) TRR
 - 55 Blue Stakes were completed
 - Golf course lake line is active @ 360 gpm
 - Weed abatement is ongoing
 - 1003 meters were read system wide
- **Open Project**
 - Golf course lake PVC valve/ pricing and completion TBD*
 - Security Fence at Cooper Morgan site/ pricing and completion TBD*
 - Installation of strategic locations for valves/ pricing and completion TBD*
 - Add level transducers to Wells/ pricing and completion TBD*
 - Rehabilitation/New well TRR #1 TBD*
 - Tasks generated from Civil Tech review

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	• September 2023	4 (2) ICR (2) TRR	• Absent
• M.A.P. testing/ PFAF's	• September 2023	• ICR/TRR POE	• Non-Detect
•	•	•	•