

ICR Water Co.

Operation Report for the Month of November 2023

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Molly way and Sterling Ranch flushing and fire pump exercise
- (3) hydrants were found leaking and have been repaired
- Attended the open November Board meeting
- System wide engineering tasks are starting
- All sites are ready for the winter temperatures
- Issues with a couple heaters, we are waiting for pricing to repair/replace. Back up heaters in place
- APS rolling black-outs caused issues at the TRR boost stations everything was taken care of with no disruption of services
- 2 new meters were installed (2) TRR
- 50 Blue Stakes were completed
- Golf course lake line is no longer taking water
- Weed abatement is complete for the season
- 1013 meters were read system wide

- **Open Project**
 - Golf course lake PVC valve/ pricing and completion TBD*
 - Security Fence at Cooper Morgan site/ pricing and completion TBD*
 - Installation of strategic locations for valves/ pricing and completion TBD*
 - Add level transducers to Wells/ pricing and completion TBD*
 - Rehabilitation/New well TRR #1 TBD*
 - Tasks generated from Civil Tech review

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	• November 2023	4 (2) ICR (2) TRR	• Absent
•	•	•	•
•	•	•	•