

ICR Water Co.

Operation Report for the Month of April 2024

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Molly way and Sterling Ranch flushing and fire pump exercise
- Received approval for solar upgrade at Whispering Canyon tank
- Catching up on some maintenance items before the season gets busy
- TRR Well #5 test pumping should be completed by the end of May
- 3 emergency call outs for ICR well #1 Switch on electrical panel was bad
- 3 meters installs (1) TRR (2) ICR
- 50 Blue Stakes were completed
- 1022 meters were read system wide

- **Open Project**

- Golf course lake PVC valve/ pricing and completion TBD*
- Security Fence at Cooper Morgan site/ pricing and completion TBD*
- Installation of strategic locations for valves/ pricing and completion TBD*
- Add level transducers to Wells/ pricing and completion TBD*
- TRR well #5 drilling to begin in 3/2024/ completed
- Test pumping of TRR well #5 should be completed 5/2024
- Tasks generated from Civil Tech review

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	April 2024	4 (2) ICR (2) TRR	Absent
•	•	•	•
•	•	•	•