

# ICR Water Co.

## Operation Report for the Month of July 2024

### Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Molly way and Sterling Ranch flushing and fire pump exercise
- Meter and valve for the bypass on ICR well #1 has been ordered
- Chlorine cabinet for ICR well #2 has been installed
- TRR Well #5 Civil Tech requests have been answered
- 2 ECO due to lightning
- 3 meters installs (2) TRR (1) ICR (1) bad meter replaced
- 32 Blue Stakes were completed
- Weed abatement is ongoing
- 1035 meters were read system wide
  
- **Open Project**
  - Golf course lake PVC valve/ pricing and completion TBD\*
  - Security Fence at Cooper Morgan site/ pricing and completion TBD\*
  - Installation of strategic locations for valves/ pricing and completion TBD\*
  - Add level transducers to Wells/ pricing and completion TBD\*
  - Tasks generated from Civil Tech review
  - TRR Well #5 completion and ADEQ approval
  - ICR Well #1 meter bypass \* waiting on parts
  
- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	July 2024	4 (2) ICR (2) TRR	Absent
• DBP's	July 2024	TRR	Waiting on results
•	•	•	•
•	•	•	•