

# ICR Water Co.

## Operation Report for the Month of August 2024

### Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Molly way and Sterling Ranch flushing and fire pump exercise
- Meter and valve for the bypass on ICR well #1 has been ordered
- Valve exercise and hydrant leak detection has started
- TRR Well #5 Civil Tech requests have been answered
- Rebuilt an ARV at Cooper Morgan boost station
- A new gable fan has been ordered for Cooper Morgan Boost station
- 1 meters installs (1) TRR
- 46 Blue Stakes were completed
- Weed abatement is ongoing
- 1042 meters were read system wide
  
- **Open Project**
- Golf course lake PVC valve/ pricing and completion TBD\*
- Security Fence at Cooper Morgan site/ pricing and completion TBD\*
- Installation of strategic locations for valves/ pricing and completion TBD\*
- Add level transducers to Wells/ pricing and completion TBD\*
- Tasks generated from Civil Tech review
- TRR Well #5 completion and ADEQ approval
- ICR Well #1 meter bypass \* waiting on parts
  
- **Water Testing**

| • Analysis Name        | • Month     | • # of samples    | • result           |
|------------------------|-------------|-------------------|--------------------|
| • Monthly Microbiology | August 2024 | 4 (2) ICR (2) TRR | Absent             |
| • DBP's                | July 2024   | TRR               | Waiting on results |
| •                      | •           | •                 | •                  |
| •                      | •           | •                 | •                  |