

ICR Water Co.

Operation Report for the Month of Nov. / Dec. 2024

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Hot tap on Double Adobe has been completed
- Molly way and Sterling Ranch flushing and fire pump exercise
- All dead end lines have been flushed
- Valve exercise and hydrant leak detection is completed for the year, all repairs are complete except 1 hydrant it is scheduled when parts arrive
- Found a leaking ARV on the transmission line from ICR wells, parts are on order
- Board has estimates for painting Magner tank
- 7 meters installs (3) TRR (4) ICR
- 110 Blue Stakes were completed
- 1050 meters were read system wide

- **Open Project**
 - Golf course lake PVC valve/ pricing and completion TBD*
 - Security Fence at Cooper Morgan site/ pricing and completion TBD*
 - Installation of strategic locations for valves/ pricing and completion TBD*
 - Add level transducers to Wells/ pricing and completion TBD*
 - Tasks generated from Civil Tech review
 - TRR Well #5 completion and ADEQ approval
 - ICR Well #1 meter bypass * completed
 - Painting of the Magner storage tank/pricing and completion TBD*

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	Nov./Dec. 2024	8(4) ICR (4) TRR	Absent
•	•	•	•