

ICR Water Co.

Operation Report for the Month of January 2025

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Leaking ARV on the ICR transmission line has been repaired
- Molly way and Sterling Ranch flushing and fire pump exercise
- All dead end lines have been flushed
- Annual maintenance on pumps and motors has been completed
- TRR well #5 tie-in is ongoing
- Board has estimates for painting Magner tank
- Took a new Board member on a tour of the systems
- 2 meters installs (2) ICR
- 58 Blue Stakes were completed
- 1048 meters were read system wide

- **Open Project**
- Golf course lake PVC valve/ pricing and completion TBD*
- Security Fence at Cooper Morgan site/ pricing and completion TBD*
- Installation of strategic locations for valves/ pricing and completion TBD*
- Add level transducers to Wells/ pricing and completion TBD*
- Tasks generated from Civil Tech review
- TRR Well #5 completion and ADEQ approval
- Painting of the Magner storage tank/pricing and completion TBD*

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	January 2025	(2) ICR (2) TRR	Absent
•	•	•	•