

# ICR Water Co.

## Operation Report for the Month of February 2025

### Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- New gate is being installed at the TRR well field
- Molly way and Sterling Ranch flushing and fire pump exercise
- All dead end lines have been flushed
- Annual maintenance on pumps and motors has been completed
- TRR well #5 project is complete and well is online pumping 340 gpm with capability to increase flow
- 10 meters installs (8) ICR (2) TRR
- 45 Blue Stakes were completed
- 1067 meters were read system wide
  
- **Open Project**
- Golf course lake PVC valve/ pricing and completion TBD\*
- Security Fence at Cooper Morgan site/ pricing and completion TBD\*
- Installation of strategic locations for valves/ pricing and completion TBD\*
- Add level transducers to Wells/ pricing and completion TBD\*
- Tasks generated from Civil Tech review
- TRR Well #5 completed
- Painting of the Magner storage tank/pricing and completion TBD\*
  
- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	February 2025	(2) ICR (2) TRR	Absent
•	•	•	•