

ICR Water Co.

Operation Report for the Month of March 2025

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- New gate is being installed at the TRR well field
- Molly way and Sterling Ranch flushing and fire pump exercise
- All dead end lines have been flushed
- Rehab work on ICR well #1 will start the first week of April
- TRR well #5 project is complete and well is online pumping 340 gpm with capability to increase flow
- Fever Controls is working on SCADA upgrades
- Well building piping has been painted
- 4 meters installs (1) ICR (3) TRR
- 58 Blue Stakes were completed
- 1067 meters were read system wide
- **Open Project**
 - Golf course lake PVC valve/ pricing and completion TBD*
 - Security Fence at Cooper Morgan site/ pricing and completion TBD*
 - Installation of strategic locations for valves/ pricing and completion TBD*
 - Add level transducers to Wells/ pricing and completion TBD*
 - Tasks generated from Civil Tech review
 - TRR Well #5 completed
 - Painting of the Magner storage tank/pricing and completion TBD*

• Water Testing

| • Analysis Name | • Month | • # of samples | • result |
|------------------------|------------|-----------------|----------|
| • Monthly Microbiology | March 2025 | (2) ICR (2) TRR | Absent |
| | | | |
| | | | |
| • | • | • | • |