

ICR Water Co.

Operation Report Jan./Feb. 2026

Overall Operations

- General maintenance and operations are on-going
- Easement roads are checked for issues with the transmission lines
- Molly way and Sterling Ranch flushing and fire pump exercise
- All wells are functioning properly at this time
- TRR well #5 equipment installed looks like about 550 gpm
- ICR well #2 equipment replaced
- Hydrant repaired on Vesta
- New Board member took a tour of system
- Fever Controls is working on SCADA upgrades
- 5 meters installs (3) ICR (2) TRR
- 93 Blue Stakes were completed
- 1106 meters were read system wide

- **Open Project**
- Golf course lake PVC valve/ pricing and completion TBD*
- Security Fence at Cooper Morgan site/ pricing and completion TBD*
- Installation of strategic locations for valves/ pricing and completion TBD*
- Add level transducers to Wells/ pricing and completion TBD*
- Tasks generated from Civil Tech review
- TRR Well #5 equipment replacement * completed

- **Water Testing**

• Analysis Name	• Month	• # of samples	• result
• Monthly Microbiology	Jan/Feb	(4) ICR (4) TRR	Absent
DBP's	July 2025 Sept 2025	TRR ICR	compliance
Lead and Copper	Sept. 2025	(5) ICR	compliance
•	•	•	•